

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 3774-1725:0103

Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** STANLEY SECURITY SOLUTIONS, 6161 E. 75th Street, Indianapolis, IN, 46250  
Contact: Robert Strong (317) 806-3288 Fax (317) 806-3337  
Email: bstrong@stanleyworks.com

**DESIGN:** Model IDH Max Access Control System electronically controlled single point lockset.  
The system consists of Model 30HW, 8KW or 9KW. For use on doors not exceeding 4  
Ft. in width and 10 Ft. in height rated up to and including 3 hours. Refer to listee's  
data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and  
ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as an access control system for use on swinging type fire doors. Authority  
having jurisdiction shall be consulted prior to installation. Refer to Manufacturer's  
Installation Instruction Manual for details.

**NOTE:** Formerly 3774-1175:107

4-2-10 MA



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **April 02, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division